Energy performance certificate (EPC)



Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's energy rating is C. It has the potential to be C.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- · the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Sandstone or limestone, with internal insulation	Good
Wall	Sandstone or limestone, as built, partial insulation (assumed)	Average
Window	Single glazed	Very poor
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, room thermostat and TRVs	Good
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Roof	(another dwelling above)	N/A
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 145 kilowatt hours per square metre (kWh/m2).

► About primary energy use

Additional information

Additional information about this property:

· Stone walls present, not insulated

How this affects your energy bills

An average household would need to spend £563 per year on heating, hot water and lighting in this property. These costs usually make up the majority of your energy bills.

You could save £67 per year if you complete the suggested steps for improving this property's energy rating

This is **based on average costs in 2025** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 3,624 kWh per year for heating
- 1,744 kWh per year for hot water

Impact on the environment

This property's environmental impact rating is C. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

Carbon emissions

This property produces	1.5 tonnes of CO2
This property's potential production	1.3 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

▶ Do I need to follow these steps in order?

Step 1: Double glazed windows

Replace single glazed windows with low-E double glazed windows

Typical installation cost £3,300 - £6,500

Typical yearly saving £66

Potential rating after completing step 1

80 C

Advice on making energy saving improvements

Get detailed recommendations and cost estimates

Speak to an advisor from Nest

Help paying for energy saving improvements

You may be eligible for help with the cost of improvements:

• Heat pumps and biomass boilers: Boiler Upgrade Scheme

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Wayne Lewis
Telephone	07967175431
Email	waynodj@gmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/030027
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

party

Date of assessment	4 March 2025
Date of certificate	8 March 2025
Type of assessment	► <u>RdSAP</u>

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

Certificate number	6839-8721-6000-0659-9226 (/energy-certificate/6839-8721-6000-0659-9226)
Valid until	21 September 2031
Certificate number	2788-2953-6280-9429-9930 (/energy-certificate/2788-2953-6280-9429-9930)
Expired on	27 October 2021

Give feedback (https://forms.office.com/e/KX25htGMX5) Service performance (/service-performance)

OGL

All content is available under the <u>Open Government Licence v3.0</u> (https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated



ht (https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framewor